



中国认可
国际互认
检测
TESTING
CNAS L0699



TEST REPORT

CEPRI-EETC02-2021-0034 (E)

Client: ZGHD ELECTRIC CO;LTD.

Object: 10kV AC plug in gapless zinc oxide arrester

Type: GHD-15BLQ




Test Category: Type Test



POWER INDUSTRY QUALITY INSPECTION AND TEST
CENTER FOR ELECTRIC EQUIPMENT

Catalogue

1.Catalogue	1
2.Signature Page	2
3.Test Results	3
4.Content.....	4
5.Appendix A Object Parameters	15
6.Appendix B The Main Test Devices	15
7.Appendix C Waveforms	16
8.Appendix D Visual and dimensional check.....	19

Test Report	Power Industry Quality Inspection and Test Center for Electric Equipment		CEPRI-EETC02-2021-0034(E) Total 20 Page 2
Client	ZGHD ELECTRIC CO;LTD.	Manufacturer	ZGHD ELECTRIC CO;LTD.
Object	10kV AC plug in gapless zinc oxide arrester	Type	GHD-15BLQ (Φ32mm×24mm)
Sampling procedure	By the client delivery	Serial No.	1arresters (001) 10 thermally prorated sections (201~210) 13 resistors (301~313) 1 housings(401) 4 dielectrically prorated section(101~104)
Test Category	Type Test	Date	2021.03.03~2021.04.29
Requirements	GB/T 11032-2020 Metal-oxide surge arresters without gaps for a.c. systems		
Conclusion	The 10kV Screened separable rear connector with arrester type GHD-15BLQ have successfully passed the type test specified in GB/T 11032-2020.		
Note	<p>Note 1: In the event of any difference in meanings of the text, the Chinese report shall take precedence over the English version.</p> <p>Note 2: Since the date of issuance, the routine test which concerns about the related content must be done every 5 years in order to extend the validity of this report.</p> <p>Note 3:See appendix A for sample instruction.</p>		
<p>Compiled by: 万克  梁菊霞 </p>			
<p>Checked by: 王陆璐  Verified by: 左中秋 </p>			
<p>Approved by: 王保山  Date of issue: 2021.06.09</p>			

Test Report	Power Industry Quality Inspection and Test Center for Electric Equipment	CEPRI-EETC02-2021-0034(E) Total 20 Page 3
-------------	---	--

Test Results					
No.	Item	Requirements	Results	Evaluation	
1	D.C. reference voltage test	$24.0\text{kV} \leq U_{1\text{mADC}} \leq 26.5\text{kV}$	25.5kV	Pass	
2	Leakage current test at 0.75 times D.C. reference voltage	$I_L(0.75U_{1\text{mADC}}) \leq 50\mu\text{A}$	6 μA	Pass	
3	Continuous operating current test	$I_x \leq 1000\mu\text{A}$ $I_R \leq 350\mu\text{A}$	$I_x = 165\mu\text{A}$ $I_R = 40\mu\text{A}$	Pass	
4	A.C.reference voltage test	$U_{1\text{mAAC}} \geq 17\text{kV}_p/\sqrt{2}$	$18.8\text{kV}_p/\sqrt{2}$	Pass	
5	Partial discharge test	Apply $1.05U_c$ withstand time 60s, the partial discharge $\leq 10\text{pC}$.	2.0pC	Pass	
6	Insulation withstand tests on the arrester housing	Power-frequency voltage: Dry $\geq 42\text{kV}$, for 1min. Lightning impulse voltage : 75.0kV_p , the positive and negative 15 times respectively.	Power-frequency voltage dry: $42.2\text{kV}_{\text{rms}}$, 1min. Lightning impulse voltage: $75.2\text{kV}_p \sim 75.7\text{kV}_p$ the positive and negative 15 times respectively.	Pass	
7	Residual voltage test	Lightning impulse	$\leq 45.0\text{kV}_p$	43.06kV _p	Pass
		Steep current	$\leq 38.3\text{kV}_p$	34.12kV _p	
		Switching impulse	$\leq 51.8\text{kV}_p$	44.90kV _p	
8	Repetitive charge transfer withstand test	10 samples should withstand 20 times 2ms long-duration current impulse and the charge value should not less than 0.2C.	$Q_{rs}: 0.220\text{C} \sim 0.229\text{C}$	Pass	
9	Test to verify long term stability under continuous operating voltage	The accelerated ageing test of resistors should be carried out according to the specified procedure.	$P_{\text{max}} - P_{\text{min}} \leq 1.3P_{\text{min}}$, $P_{\text{max}} \leq 1.1P_{\text{start}}$; the samples fulfilled the requirements.	Pass	
10	Heat dissipation behavior verification test	The test section is for all instants during the cooling period have a temperature higher than the complete arrester.	Fulfilled the requirements. See fig 2.	Pass	
11	Operating duty test	Long-duration current impulse 2 times 、 Rated thermal energy injection $Q_{th} \geq 0.7\text{C}$ The residual voltage shall not have changed by more than 5%.	$Q_{th} \geq 0.707\text{C}$ The residual voltage changed ratio is from +0.47% to +1.28%.	Pass	

Test Report		Power Industry Quality Inspection and Test Center for Electric Equipment		CEPRI-EETC02-2021-0034(E) Total 20 Page 4	
12	Power-frequency voltage-versus-time characteristics	$Q_{th} \geq 0.7C$; Supply the Power frequency voltage-versus-time characteristics for the range of voltage from $1.20U_r^*$ to $1.00U_r^*$, the range of time from 0.1s to 1200s for with prior duty, $1.20U_r^*$ to $1.05U_r^*$, the range of time from 1.1s to 1200s for without prior duty.	$Q_{th} \geq 0.703C$ With prior duty test $1.20U_r^*$ 0.1s $1.15U_r^*$ 1.1s $1.10U_r^*$ 10.1s $1.00U_r^*$ 1200s	Without prior duty test $1.20U_r^*$ 1.1s $1.05U_r^*$ 1200s	Pass
13	Test to verify the dielectric withstand of the internal components of an arrester	1 time 65kA-4/10 μ s	64.1kA, no puncture, flashover, cracking or other significant damage.		Pass
(No content in this page below)					

Test Report	Power Industry Quality Inspection and Test Center for Electric Equipment	CEPRI-EETC02-2021-0034(E) Total 20 Page 5
--------------------	---	--

Content:

1~2 D.C. reference voltage test and leakage current at 0.75 times D.C. reference voltage test

Environment temperature: 12.0°C humidity:63%

Samples	D.C. reference voltage U_{1mADC} kV		0.75times D.C. reference voltage kV		Leakage current μA	
	Measured value	Specified value	Measured value	Specified value	Measured value	Specified value
001	25.5	$24.0 \leq U_{1mADC} \leq 26.5$	19.1	$0.75U_{1mADC} \pm 1\%$	6	≤ 50

Note: The standard only provides the D.C. reference voltage lower limit. The upper limit declared by the manufacturer is used to determine the proportion of the arrester protection level.

Fulfilled the requirements.

3~4 Power-frequency reference voltage test and Continuous current test

Environment temperature: 28.5°C humidity:58%

Samples	The power-frequency reference voltage U_{1mAAC} $kV_p / \sqrt{2}$		I_R μA_p		I_X μA_{rms}	
	Measured value	Specified value	Measured value	Specified value	Measured value	Specified value
001	18.8	≥ 17	40	≤ 200	165	≤ 1000

Note1: The client claims the power frequency reference current is 1mA.

Note2: The standard specifies the continuous current through the arrester shall not exceed the manufacturer's declared value.

Fulfilled the requirements.

5 Partial discharge test

Samples	U_r	U_r duration time	$1.05U_c$	$1.05U_c$ duration time	Partial discharge
	kV_{rms}	s	kV_{rms}	s	pC
001	17.0	10	14.4	60	2.0
specified value	17.0	2~10	14.3	60	≤ 10

Fulfilled the requirements.

Test Report	Power Industry Quality Inspection and Test Center for Electric Equipment	CEPRI-EETC02-2021-0034(E) Total 20 Page 6
-------------	--	--

6 Housing insulation withstand test

6.1 Power frequency voltage withstand test

t=17.0°C RH=76% Atmospheric pressure: 100.2kPa

Samples	Specified value	Applied voltage	Duration	Test result
	kV	$kV_p / \sqrt{2}$	s	
401	42(dry)	42.2	60	No flashover

Fulfilled the requirements.

6.2 Lightning impulse voltage withstand test

t=17.0°C RH=76% Atmospheric pressure: 100.2kPa

Samples	Specified value		Applied voltage	Withstand times	Test result
		kV	kV_p		
401	(+)	75.0	75.2~75.7	15	No breakdown, no flashover
	(-)	75.0	75.2~75.6	15	No breakdown, no flashover

Fulfilled the requirements.

(No content in this page below)

7 Residual voltage test

7.1 Lightning impulse current residual voltage test

Samples			301	302	303
Resistor	U_{1mADC}	kV	5.25	5.25	5.25
	8/20 μ s, 2.5kA	kV _p	7.89	7.87	7.89
	8/20 μ s, 5kA	kV _p	8.53	8.53	8.52
	8/20 μ s, 10kA	kV _p	9.43	9.44	9.41
	U_{5kA}/U_{1mADC}	-	1.62	1.62	1.62
Complete arrester	U_{1mADC}	kV	$24.0 \leq U_{1mADC} \leq 26.5$		
	Scale coefficient	-	5.05	5.05	5.05
	Lightning impulse protection level	kV _p	43.06		
	Specified value	kV _p	≤ 45.0		

Note 1: Shunt 0.025 V/A, divider $K_d=203.1$

Note 2: According to the determined residual pressure, draw the residual voltage and current curve, in the curve corresponding to the nominal discharge current read residual voltage, defined as the lightning protection lightning protection level.

7.2 Switching impulse current residual voltage test

Samples			301	302	303
Resistor	Residual voltage at 250A	kV _p	6.74	6.76	6.74
Complete arrester	Scale coefficient	-	5.05	5.05	5.05
	Test value	kV _p	34.02	34.12	34.02
	Specified value	kV _p	≤ 38.3		

Note: Shunt 0.025 V/A, divider $K_d=203.1$

7.3 Steep impulse current residual voltage test

Samples			301	302	303
Resistor	5 kA U_{res1}	kV _p	9.09	9.08	9.06
	5 kA U_{res2}	kV _p	0.23		
	U_{res2}/U_{res1}	%	2.5	2.5	2.5
	$U_{res1}-U_{res2}$	kV _p	8.86	8.85	8.83
Complete arrester	Scale coefficient	-	5.05	5.05	5.05
	Residual voltage for the arrester	kV _p	44.7	44.7	44.6
	Inductance per unit length	μ H/m	0.3		
	Height without resistors	m	$0.2355-(0.024 \times 5)=0.116$		
	Inductive voltage correction	kV _p	$0.3 \times 0.116 \times 5=0.17$		
	Residual voltage for the arrester after correction	kV _p	44.90	44.80	44.70
Specified value	kV _p	≤ 51.8			

Note1: Shunt 0.0267 V/A, divider $K_d=59.0$.

Note 2: If U_{res2}/U_{res1} is less than 2%, there is no need to correct Inductive effect.

Fulfilled the requirements. Test waveform is shown in appendix C fig C.1~ fig C.3.

8 Repetitive charge transfer withstand

Samples:10 resistors (304~313)

Requirements of standards: The samples should withstand more than 0.2C by 8/20us current impulse for 20 times, and after test, have no breakdown or flashover or breakage, the change of residual voltage within $\pm 5\%$, the change of reference voltage within $\pm 5\%$, also should withstand capability to one 8/20us current impulse of at least 0.5 kA/cm² peak current density or 2 times I_n, whichever is lower.

Test data: Fulfilled the requirements , the test waveforms were shown in appendix C fig C.4.

Samples		304	305	306	307	308	309	310	311	312	313
Before test	U _{ImAAC} , kV	3.96	3.89	3.90	3.90	3.87	3.88	3.90	3.91	3.88	3.89
	8/20μs U _{5kAp} , kV	8.66	8.63	8.64	8.63	8.60	8.61	8.63	8.65	8.60	8.62
Q _{rs} , C		Q _{rs} (Claimed repetitive charge transfer rating) * 1.1=0.22									
1 st	Q _{rs} , C	0.224	0.222	0.226	0.222	0.223	0.224	0.227	0.227	0.225	0.224
2 nd	Q _{rs} , C	0.226	0.226	0.227	0.226	0.226	0.227	0.222	0.226	0.226	0.227
3 rd	Q _{rs} , C	0.222	0.223	0.222	0.227	0.226	0.222	0.227	0.221	0.222	0.222
4 th	Q _{rs} , C	0.226	0.226	0.223	0.222	0.227	0.225	0.225	0.228	0.223	0.221
5 th	Q _{rs} , C	0.224	0.222	0.226	0.223	0.228	0.223	0.228	0.223	0.224	0.223
6 th	Q _{rs} , C	0.226	0.226	0.225	0.226	0.229	0.226	0.222	0.227	0.225	0.224
7 th	Q _{rs} , C	0.223	0.227	0.223	0.225	0.224	0.222	0.225	0.222	0.221	0.226
8 th	Q _{rs} , C	0.222	0.222	0.222	0.227	0.223	0.227	0.226	0.221	0.222	0.222
9 th	Q _{rs} , C	0.228	0.228	0.226	0.222	0.226	0.226	0.227	0.224	0.226	0.223
10 th	Q _{rs} , C	0.226	0.223	0.228	0.228	0.225	0.225	0.229	0.228	0.223	0.226
11 th	Q _{rs} , C	0.222	0.223	0.229	0.226	0.222	0.224	0.221	0.226	0.221	0.227
12 th	Q _{rs} , C	0.223	0.228	0.227	0.224	0.228	0.222	0.223	0.227	0.226	0.228
13 th	Q _{rs} , C	0.222	0.227	0.223	0.222	0.227	0.227	0.222	0.221	0.222	0.221
14 th	Q _{rs} , C	0.226	0.222	0.226	0.221	0.226	0.226	0.227	0.228	0.227	0.226
15 th	Q _{rs} , C	0.225	0.226	0.227	0.226	0.223	0.222	0.226	0.226	0.224	0.221
16 th	Q _{rs} , C	0.223	0.228	0.226	0.228	0.222	0.225	0.229	0.223	0.220	0.222
17 th	Q _{rs} , C	0.227	0.227	0.225	0.227	0.224	0.223	0.228	0.222	0.226	0.227
18 th	Q _{rs} , C	0.226	0.225	0.228	0.228	0.225	0.222	0.223	0.224	0.223	0.228
19 th	Q _{rs} , C	0.226	0.222	0.224	0.223	0.221	0.226	0.228	0.223	0.227	0.225
20 th	Q _{rs} , C	0.222	0.223	0.226	0.228	0.224	0.227	0.226	0.221	0.222	0.224

Test evaluation	One 8/20 current impulse, kA	4.02 kA $(0.5\text{kA}/\text{cm}^2=0.5 \times 3.14 \times (3.2/2)^2=4.02\text{kA}$ which is lower than 2 times I_n)									
	U_{1mAAC} , kV	4.06	4.08	4.06	4.10	4.09	4.06	4.05	4.03	4.04	4.02
	Change rate, %	3.82	3.73	3.75	3.76	3.73	3.71	3.75	3.75	3.76	3.75
	8/20 μ s U_{5kAp} , kV	-3.29	-4.11	-3.85	-3.59	-3.62	-4.38	-3.85	-4.09	-3.09	-0.60
	Change rate, %	8.56	8.52	8.55	8.52	8.51	8.49	8.55	8.56	8.56	8.57
	Change rate, %	-1.15	-1.27	-1.04	-1.27	-1.05	-1.39	-0.93	-1.04	-0.47	-0.58
Visual inspection	All the samples have no puncture, flashover or cracking.										

9. Test to verify long term stability under continuous operating voltage

Samples: 3 dielectrically prorated sections(101~103)

Requirements of standards: 3 resistors should pass the accelerated ageing test.

Test data: Fulfilled the requirements, the accelerated ageing curves were shown in fig 1.

Samples	101	102	103
U_{1mADC} , kV	5.05	5.04	5.08
U_c , kV _{rms}	3.05 85.1		
Power losses P_{start} , 3h, W	0.320	0.329	0.255
Power losses P_{100h} , W	0.297	0.306	0.245
Power losses P_{200h} , W	0.296	0.307	0.246
Power losses P_{300h} , W	0.286	0.297	0.239
Power losses P_{400h} , W	0.309	0.317	0.248
Power losses P_{500h} , W	0.261	0.278	0.237
Power losses P_{600h} , W	0.283	0.294	0.251
Power losses P_{700h} , W	0.269	0.285	0.229
Power losses P_{800h} , W	0.288	0.305	0.249
Power losses P_{900h} , W	0.296	0.297	0.240
Power losses P_{end} , 1000+8h, W	0.272	0.281	0.226
P_{max} , W	0.320	0.329	0.255
P_{min} , W	0.261	0.278	0.226
$(P_{max} - P_{min}) / 1.3P_{min}$	0.174	0.141	0.099
$P_{max} / 1.1 P_{start}$	0.91	0.91	0.91

Note: (1) Because $(P_{max} - P_{min}) < 1.3P_{min}$, $P_{max} < 1.1 P_{start}$, the samples fulfilled the requirements.
(2) The temperature of blocks: 115 ± 4 °C. Note 2: Resistor temperature: 115 ± 4 °C.




Fig 1 Accelerated ageing test curve

10 Heat dissipation behavior verification of test sample

Samples: 1 thermally prorated section (210), 1 arrester (001)

Requirements of standards: the MO resistors in the sample shall be heated to 140°C by the application of power-frequency voltage. When the temperature is reached, the voltage source shall be disconnected and the cooling time curve shall be determined. At any time, the measured cooling curve of section falls shall above the measured cooling curve of the arrester.

Test data: Fulfilled the requirements, the test waveform was shown in fig 2.




Fig 2 The cooling curve for the section and arrester

Test Report	Power Industry Quality Inspection and Test Center for Electric Equipment		CEPRI-EETC02-2021-0034(E) Total 20 Page 11			
11 Operating duty test						
Samples: 3 thermally prorated sections (201~203)						
Requirements of standards: 3 thermally prorated sections should pass the high current impulse operating duty test.						
Test data: Fulfilled the requirements, the test waveforms were shown in appendix C fig C.5~fig C.6.						
Samples		201	202	203		
U_{1mADC} , kV		5.27	5.27	5.27		
U_{sr} , kV_{rms}		3.73	3.73	3.73		
U_{sc} , kV_{rms}		2.99	2.99	2.99		
8/20 μ s, U_{5kA} , before, kV		8.57	8.58	8.57		
Conditioning test	1 st high current impulse, kA	63.6	64.2	64.2		
	2 nd high current impulse, kA	64.8	63.8	65.1		
preheated samples		preheated samples to 60.0°C±3°C				
Rated thermal energy injection, W_{th}	Lightning current impulse	1 st Q_{th} , C	0.357	0.358	0.352	
		2 nd Q_{th} , C	0.352	0.356	0.355	
	Q_{th} rating (2 times), C	0.709	0.714	0.707		
Applied voltage after the 3 rd impulse	Time	Req.	as short as possible (within 100ms)			
		Actual	82	78	82	
	Applied voltage and duration	U_{sr}^* , kV_{rms}	3.73	3.73	3.73	
		Duration, s	10	10	10	
		U_{sc}^* , kV_{rms}	2.99	2.99	2.99	
Duration, min	30	30	30			
Power loss, W	1 s		4.27	4.61	4.18	
	5 min		3.12	3.57	3.27	
	10 min		2.42	2.72	2.68	
	15 min		2.06	2.29	2.12	
	20 min		1.78	1.94	1.88	
	25 min		1.54	1.68	1.62	
	30 min		1.39	1.53	1.45	
Samples cooled to		cooled to ambient 20°C±15°C				
8/20 μ s, U_{5kA} , after, kV		8.65	8.69	8.61		
Variability of the residual voltage, %		+0.93	+1.28	+0.47		
Visual inspection		No puncture, flashover, cracking or other significant damage				

Test Report	Power Industry Quality Inspection and Test Center for Electric Equipment		CEPRI-EETC02-2021-0034(E) Total 20 Page 12			
12 Power-frequency voltage-versus-time test						
12.1 Power-frequency voltage-versus-time test data (with prior duty)						
Samples			204	205	206	207
U_{1mADC} , kV			5.28	5.28	5.28	5.29
U_{sr} , kV _{rms}			3.74	3.74	3.74	3.75
U_{sc} , kV _{rms}			2.99	2.99	2.99	3.00
8/20 μ s, U_{5kA} , before, kV			8.60	8.61	8.61	8.64
preheated samples			preheated samples to 85°C±3°C			
2ms long-duration current impulse	1 st impulse	Q_{th} , C	0.356	0.352	0.358	0.356
	2 nd impulse	Q_{th} , C	0.354	0.351	0.353	0.357
	Q_{th} rating (2 times), C		0.710	0.703	0.711	0.713
Applied voltage after the 3 rd impulse	Time	Req.	as short as possible (within 100ms)			
		Actual	78	82	82	78
	Applied voltage and duration	U_{sr}^* , kV _{rms}	4.49	4.30	4.11	3.75
		TOV scale	1.20	1.15	1.10	1.00
		Duration, s	0.1	1.10	10.1	1200
		U_{sc}^* , kV _{rms}	2.99	2.99	2.99	3.00
	Duration, min	30	30	30	30	
Power loss, W	1 s		3.52	4.06	5.46	3.96
	5 min		3.06	3.15	4.29	3.13
	10 min		2.47	2.54	3.32	2.77
	15 min		2.26	2.08	2.78	2.23
	20 min		2.07	1.72	2.33	2.01
	25 min		1.92	1.56	2.07	1.84
	30 min		1.87	1.39	1.98	1.76
Samples cooled to			cooled to ambient 20°C±15°C			
8/20 μ s, U_{5kA} , after, kV			8.66	8.72	8.76	8.71
Variability of the residual voltage, %			+0.70	+1.29	+1.74	+0.81
Visual inspection			No puncture, flashover, cracking or other significant damage			
Fulfilled the requirements, the test waveforms were shown in appendix C fig C.7~C.9.						

Test Report		Power Industry Quality Inspection and Test Center for Electric Equipment		CEPRI-EETC02-2021-0034(E) Total 20 Page 13	
12.2 Power-frequency voltage-versus-time test data (without prior duty)					
Samples		208		209	
U_{1mADC} , kV		5.29		5.29	
U_{sr} , kV _{rms}		3.75		3.75	
U_{sc} , kV _{rms}		3.00		3.00	
8/20 μ s, U_{5kA} , before, kV		8.64		8.66	
preheated samples		preheated samples to 60.0°C±3°C			
Applied voltage	Applied voltage and duration	U_{sr}^* , kV _{rms}	4.50	3.75	
		TOV scale	1.20	1.00	
		Duration, s	1.1	1200	
		U_{sc}^* , kV _{rms}	3.00	3.00	
		Duration, min	30	30	
Power loss, W	1 s	3.20		2.58	
	5 min	2.72		2.03	
	10 min	2.27		1.66	
	15 min	2.83		1.37	
	20 min	2.39		1.15	
	25 min	1.96		0.98	
	30 min	1.67		0.82	
Samples cooled to		cooled to ambient 20°C±15°C			
8/20 μ s, U_{5kA} , after, kV		8.68		8.69	
Variability of the residual voltage, %		+0.46		+0.35	
Visual inspection		No puncture, flashover, cracking or other significant damage			
Fulfilled the requirements, the test waveforms were shown in appendix C fig C.10.					
(No content in this page below)					

Test Report	Power Industry Quality Inspection and Test Center for Electric Equipment	CEPRI-EETC02-2021-0034(E) Total 20 Page 14
-------------	---	---

13 Test to verify the dielectric withstand of the internal components of an arrester

Samples: 1 dielectrically prorated section (104)

Requirements of standards: preheat the sample to 60°C, consists of one application of a 100kA high-current impulse.

There should be no evidence of a dielectric breakdown. The the test waveforms were shown in appendix C fig C.10.

Sample	104		
U _{1mAAC} , kV	8.61		
preheated samples	preheated samples to 60°C±3°C		
high-current impulse, kA	64.1		
Samples cooled to	cooled to ambient 20°C±15°C		
8/20μs, U _{10kA} , after, kV	8.58		
Variability of the residual voltage, %	-0.35		
Visual inspection	The block can not remove from the section	8/20μs current impulse, 2 times	4.02 kA ($0.5\text{kA}/\text{cm}^2=0.5 \times 3.14 \times (3.2/2)^2=4.02\text{kA}$ which is lower than 2 times I _n)
		1 st impulse, kA _p	4.08
		2 nd impulse, kA _p	4.10
		Curve check	No puncture, flashover, cracking or other significant damage

(No content in this page below)

Test Report	Power Industry Quality Inspection and Test Center for Electric Equipment	CEPRI-EETC02-2021-0034(E) Total 20 Page 15
--------------------	---	---

Appendix A: Object Parameters

Rated voltage U_r : 17kV Continuous operating voltage U_c : 13.6kV_{rms}
Nominal discharge current I_n : 5kA Lightning impulse residual voltage: U_{res} : $\leq 45kV_P$

Sample instruction:

①1 arrester, number EETC02-21/02/15-0034-001, short for 001 in report; ②10 thermally prorated sections, number EETC02-21/02/15-0034-201~ EETC02-21/02/15-0034-210 short for 201~210 in report; ③13 resistors, number EETC02-21/02/15-0034-301~ EETC02-21/02/15-0034-313, short for 301~313 in report; ④1 housings, number EETC02-21/02/15-0034-401, short for 401 in report.⑤4 dielectrically prorated sections, number EETC02-21/02/15-0034-101~ EETC02-21/02/15-0034-104, short for 101~104 in report.

Appendix B: Main test device

NO.	Device name	Device NO.	Measurement	Uncertainty /Accuracy	Calibration institution	Expiration date
1	impulse current generator	EETC02-0003	8/20 μ s 40 kA 4/10 μ s 130 kA	$U_{rel}=0.015$ k=2	National center for high voltage measurement	2021-06-04
2	impulse current generator	EETC02-0005	8/20 μ s 40 kA, 30kV 30/80 μ s 12kA, 30kV	$U_{rel}=0.015$ k=2 $U_{rel}=0.019$ k=2	National center for high voltage measurement	2021-06-04
3	800kV impulse voltage generator	EETC02-0007	0~800 kV 0~20 kA	$U_{rel}=0.013$ k=2	National center for high voltage measurement	2021-06-04
4	400kV DC high voltage generator	EETC02-0008	0~400 kV	$U_{rel}=0.012$ k=2	National center for high voltage measurement	2021-07-13
5	Operating duty test system-voltage	EETC02-0009	0~10kV	$U_{rel}=0.012$ k=2	Beijing Aerospace measurement and testing technology institute	2021-11-03
6	Salt spray test chamber	EETC02-0023	0-200 $^{\circ}$ C 0-100g/cm2	$U_{rel}=0.3^{\circ}$ C k=2 $U_{rel}=0.1g$ k=2	Hubei province meteorological metrological verification station	2021-09-10
7	UV light test chamber	EETC02-0027	/	$U_{rel}=0.3^{\circ}$ C k=2 $U_{rel}=20\%$ k=2	Hubei province meteorological metrological verification station	2022-01-04
8	Bending test machine	EETC02-0031	0-20kN	$U_{rel}=0.3\%$ k=2 $U_{rel}=0.3\%$ k=2	Hubei province meteorological metrological verification station	2021-09-10
9	Thermal-humidity test chamber	EETC02-0029	-45~100 $^{\circ}$ C	$U_{rel}=0.3^{\circ}$ C k=2	Hubei province meteorological metrological verification station	2021-09-10
10	JFD-251 PD tester	EETC02-0043	/	$U_{rel}=0.015$ k=2	Beijing Aerospace measurement and testing technology institute	2021-08-15
11	Temperature measuring system	EETC02-0053	0-150 $^{\circ}$ C	$U_{rel}=0.2^{\circ}$ C k=2	Hubei province meteorological metrological verification station	2021-12-11

Appendix C: Waveforms




Fig C.1 Lightning impulse current and residual voltage waveform (sample 301, shunt 0.025V/A, divider $K_d=203.1$)




Fig C.2 Switching impulse current and residual voltage waveform (sample 301, shunt 0.025V/A, divider $K_d=203.1$)




Fig C.3 Steep impulse current and residual voltage waveform (sample 301, shunt 0.0267V/A, divider $K_d=59.0$)




Fig C.4 The 1st time of sample 304, Repetitive charge transfer withstand, 0.01V/A




Fig C.5 Waveform of 201 conditioning test (first impulse)




Fig C.6 Operating duty waveform, sample 201, $K_d=1540$




Fig C.7 Power-frequency voltage-versus-time test waveform, sample 204, $K_d=1540$




Fig C.8 Power-frequency voltage-versus-time test waveform, sample 205, $K_d=1540$




Fig C.9 Power-frequency voltage-versus-time test waveform, sample 206, $K_d=1540$



Fig C.10 Power-frequency voltage-versus-time test waveform, sample 208, $K_d=1540$

Appendix D: Visual and dimensional check



Fig. D1 GHD-15BLQ type arrester and resistor




Fig D2 : Dimensional drawing of GHD-15BLQ